

APPENDIX - XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1362

Dated: 22-2-24

It is certified that an inspection team headed by ...Narendra Verma.....
(Name of Officers with designation) fromAsst. Eng. (PHED), Surat City, Pali.....
(Name of Department/ Office) inspected the GOKUL SCHOOL CHANDAWAL
MURDAWA ROAD.
(Name & Address of the school) on 20-2-24.....(date of inspection) and found that the
GOKUL SCHOOL CHANDAWAL (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of One (1) year.

JEN

Signature with Seal:

Name :

Designation :

Name & Address of the Office / Department :

To

GOKUL SCHOOL,
MURDAWA ROAD,
CHANDAWAL NAGAR - 306306
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Principal
PRINCIPAL
GOKUL SCHOOL
CHANDAWAL (PALI)

NDavish
सचिव
गोकुल स्कूल चण्डावल



OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY PALI

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech(Chem) 1265-1266

Dated: 15/02/2024

To,

Assistant Engineer
PHED Sub Dn.
Sojat City

District: Pali
Block: Sojat

Reference: Your Letter No. 1338

Dated: 12-02-2024 Name of Sample Taker: Helper

Date of Receipt: 12-02-2024

Ref ID: 419

Source	TW	Treated			
Source Location	Murdawa Road Gokul School TW	Murdawa Road Gokul School TW			
Habitation	Chandawal Nagar	Chandawal			
Village/Town	Chandawal	Chandawal			
Gram Panchayat	Chandawal	Chandawal			
Date of Collection	07-02-2024	07-02-2024			
Date of Examination	13-02-2024	13-02-2024			
Lab. Sample No.	4791	4792			
Note :- All results Except pH are in mg/L					
1 pH	8.5	8.4			
2 Turbidity(NTU)	Clear	Clear			
3 Colour	None	None			
4 Odour	ND	ND			
5 Temperature (°C)	25	25			
6 Total Alkalinity (as CaCO ₃)	460	120			
7 Total Hardness (as CaCO ₃)	340	140			
8 Calcium Hardness (as CaCO ₃)	180	80			
9 Magnesium Hardness (as CaCO ₃)	160	60			
10 Chloride (as Cl ⁻)	580	80			
11 Sulphate (as SO ₄ ⁻²)	-	-			
12 Nitrite (as NO ₂ ⁻)	-	-			
13 Nitrates (as NO ₃ ⁻)	32	10			
14 Fluoride (as F ⁻)	0.98	1.21			
15 Total Dissolved Solids	1998	280			
16 Residual Chlorine	-	-			

No. Lab/Tech(Chem) 1265-1266

Copy to:

- 1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
- 2 The Executive Engineer, PHED Division, Pali/Sojat/Falna
- 3

PRINCIPAL
GOKUL SCHOOL
CHANDAWAL (PALI)

Senior Chemist
PHED Lab Pali

Dated: 15/02/2024

Senior Chemist

सचिव

गोकुल स्कूल चण्डावल