

11/12

APPENDIX - XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1362

Dated: 22-2-24

It is certified that an inspection team headed by Narendra Verma

(Name of Officers with designation) from Asst. Eng. (PHED), Sajat City, Pali

(Name of Department/ Office) inspected the GOKUL SCHOOL, CHANDAWAL
MURDAWA ROAD.

(Name & Address of the school) on 20-2-24 (date of inspection) and found that the GOKUL SCHOOL, CHANDAWAL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one (1) year.

JEN

Signature with Seal: [Signature]

Name : जन.सं. अभियंता

Designation : उपखण्ड सैजत नगर (प)

Name & Address of the Office / Department :

To
GOKUL SCHOOL,
MURDAWA ROAD,
CHANDAWAL NAGAR - 306306
(Name & Address of the Institution)

[Signature]
सचिव
गोकुल स्कूल चण्डावल

[Signature]
PRINCIPAL
GOKUL SCHOOL
CHANDAWAL (PALI)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY PALI

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech(Chem) 860.

Dated: 22/07/2024

To,

Principal
Gokul School, Chandawal Murdawa Road
Sojat City

District: Pali
Block: Sojat

The sample was not collected
by this laboratory

Reference : Your Letter No. NIL

Dated: 22-07-2024 Name of Sample Taker: Shri Rakesh Rai

Date of Receipt : 22-07-2024

Ref ID: 157

Source	TW	Treated		
Source Location	Gokul School, Murdawan Road, Chandawal Nagar	Gokul School, Murdawan Road,		
Habitation	Chandawal Nagar	Chandawal		
Village/Town	Chandawal	Chandawal		
Gram Panchayat	Chandawal	Chandawal		
Date of Collection	22-07-2024	22-07-2024		
Date of Examination	22-07-2024	22-07-2024		
Lab. Sample No.	1888	1889		
Note :- All results Except pH are in mg/L				
1	pH	8.4	8.2	
2	Turbidity(NTU)	Clear	Clear	
3	Colour	None	None	
4	Odour	ND	ND	
5	Temperature (°C)	25	25	
6	Total Alkalinity (as CaCO ₃)	440	160	
7	Total Hardness (as CaCO ₃)	360	140	
8	Calcium Hardness (as CaCO ₃)	240	80	
9	Magnesium Hardness (as CaCO ₃)	120	60	
10	Chloride (as Cl ⁻)	580	60	
11	Sulphate (as SO ₄ ⁻²)	-	-	
12	Nitrite (as NO ₂ ⁻)	-	-	
13	Nitrates (as NO ₃ ⁻)	45	8	
14	Fluoride (as F ⁻)	0.88	1.08	
15	Total Dissolved Solids	2000	288	
16	Residual Chlorine	-	-	

Not Valid for Water
Quality Legal Cases

Senior Chemist
PHED Lab Pali
Dated: 22/07/2024

No. Lab/Tech(Chem)

Copy to:

- 1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
- 2 The Executive Engineer, PHED Division, Pali/Sojat/Falna
- 3

सचिव
गोकुल स्कूल चण्डावल

PRINCIPAL
GOKUL SCHOOL
CHANDAWAL (PALI)

Senior Chemist